


# Exhibit 1

**PINCHIN**  
**ENVIRONMENTAL**

  
THE PINCHIN GROUP

 Professional Engineers  
Ontario

March 26, 2003

Carleton University  
1125 Colonel By Drive  
Ottawa, ON K1S 5B6

Attention: *Tony Lackey*

**Re: Identification of Fireproofing from 1125 Colonel By Drive**  
**Pinchin File: 21065**

Dear: Mr. Tony Lackey


This letter will provide the written confirmation that, in our expert opinion, the building mentioned above contains(ed) a product manufactured by W.R. Grace Limited known by the trade name "Monokote MK-3".

This identification is based on a visual examination of the material, the analysis of the material by Polarized Light Microscope and a knowledge of the type and manufacturers of asbestos-containing fireproofing with these characteristics in Canada at the time the fireproofing was applied.

Please contact the undersigned if we can provide further information.

Yours truly,

**Pinchin Environmental Ltd.**



Dr. Donald Pinchin  
*President*  
Hazardous Materials  
905-712-6470  
dpinchin@pinchin.com